

Installers & Inspectors

THESE COLORLOGIC® ACCENT LUMINAIRES ARE UL LISTED AND HAVE BEEN EVALUATED FOR USE IN BOTH WET AND DRY APPLICATIONS. THESE LUMINAIRES ARE PERMITTED TO BE INSTALLED INSIDE OF 1½” STANDARD PVC PIPE WITHIN 10 FEET OF A WATER CONTAINING VESSEL.

THE COLORLOGIC ACCENT LUMINAIRE IS A COMPLETELY NONMETALLIC LOW VOLTAGE LIGHT. THIS DOES NOT REQUIRE BONDING OR GROUNDING WHEN POWERED BY A LISTED POOL/SPA TRANSFORMER AND INSTALLED PER THE NATIONAL ELECTRICAL CODE.

UNBONDED LIGHTING NEC PROVISIONS: When these UL Listed low voltage nonmetallic luminaires are installed in 1.5” PVC, the 2011 National Electric Code (NEC) provides an exception to luminaire bonding and grounding in Article 680.6 and 680.23.

POOL WATER BONDING NEC PROVISIONS: For Pool Water Bonding required by Article 680.26C, Concrete pools are considered conductive (see 680.26(B)(1)) due to the porosity of concrete and the bonding of rebar. No Additional bonding is required. For assistance with NEC compliance questions, contact a Hayward Senior Application Engineer at 888-898-9674. For all other product installation or usage assistance, contact Hayward Technical Support at 888-429-9273.

The complete UL Listed ColorLogic System:

Non-conductive, 2 Wire, Sealed, 12V, non-metallic with unbreakable lens and no serviceable parts.

LACUS11xxx LACUN11xxx
LYCUS11xxx LYCUN11xxx

Hayward 300 watt transformer:
LTBUY11300

Hayward 70 and 140 watt pool and spa junction box transformer retrofit kit :

LRBUY11H65 LRBUY11P65
LRBUY11M65 LRBUY11M13
LRBUY11T65

Hayward 70 watt junction box transformer:

LTBUY11H65

Non-conductive wall fittings and trim rings:

SP0536
SP0537
SP0538